

GENERAL:

1.	R 308.4	Safety glass (Temp.)
2.	R 502.2.1	Fasteners not subject to withdraw at deck ledger. Use bolts or design.
3.	R 310	Escape/rescue window clear opening to be min. 24" high, min. 20" wide, min 5.7 sq. ft. and min 44" from finished floor.
4.	R 502.11 R 802.10.5	Solid blocking to be at bearing point of trusses and rafters with uplift connection of 175 lbs on the truss.
5.	R502.7 R 802.8	Floor joists, ceiling joists and rafters to be blocked at bearing points.
6.	R 602.10.8	Blocking or joist under interior brace wall panel.
7.	R 602.6 R 602.7	Notching & Boring
8.	R 602.10	Exterior brace wall panels (BWP) & interior brace wall panels (IBWP)
9.	R 602.10.7	Full depth solid blocking at horizontal edges on IBWP's and BWPS
10.	R 802.2	Beam fails provide code complying fix to Building Dept. before installation.
11.	R 703.9	Flashing per R703.8. (windows, doors, chimneys, deck ledgers.
12.	ICC 17.03.180	Eaves 18" max.
13.	R 905.2.7	2 layers 15 lbs. felt on 2:12-4:12 roof pitch.
14.	R 703.7	Veneer to meet Chpt. 7 of the IRC
15.	R 807	Insulate, weather strip 22" X 30" attic access. WSEC 502.4.3