

STAIRS:

16.	R 311.5.6	Handrails per IRC – 34" to 36", stairs 36"min.
17.	R 312	Guardrails per IRC – 36" min.
18.	R 303.6	Stairway lighting: switch at top and bottom, 1 Ft. candle at floor / treads
19.	R 311.5	Stair: riser 7-3/4" max, run 10" min. from nose to nose. Special nosing configuration.
20.	R 311.5.3.2	Minimum tread of 6" on winders, with minimum tread of 10" @ 12" away, not to vary more than 3/8" from the largest to the 6 smallest. See Code.

PLUMBING:

21.	UPC 909	Island sink venting to meet UPC 909
22.	UPC 807.4	Air gap at dishwasher.
23.	UPC 412.11	Shower head should not discharge at entrance.